

Confidence Testing Company

Name: _____

Address: _____

Phone: _____



PIERCE COUNTY FIRE PREVENTION BUREAU

2401 SOUTH 35TH STREET
TACOMA WA 98409
253-798-7179 OFFICE
253-798-2731 FAX

FOR UNINCORPORATED PIERCE CTY BUSINESSES ONLY NOT IN CITY LIMITS

Automatic Sprinklers- Wet (one System per Report)	Certification Given		
	Red <input type="checkbox"/>	Yellow <input type="checkbox"/>	White <input type="checkbox"/>

Occupancy Address: _____ Occupancy Name: _____

Building Owner: _____ Phone Number: _____

Responsible Person: _____ Phone Number: _____

Building Owner Address: _____

Date of Inspection: _____ Inspection Frequency/Type: Annual Acceptance

Testers Name (please print) & Phone Number _____

Central Station Monitoring Yes No Monitoring Company Name: _____

System Manufacturer: _____ System Model Number: _____

Location of System: _____ System ID Number: _____

Problems Found: (If additional room is needed, please add a separate sheet)

Corrections Made: (If additional room is needed, please add a separate sheet)

Date Corrected: _____ **Corrected By:** _____

This certifies that this fire and life safety system has been properly inspected for reliability to cover the items listed in the report and is consistent with the International Fire Code standards, and that discrepancies are noted and have been reported to the building Owner/Manager for corrective action.

Signature of Tester: _____ Phone #: _____

Testing Agency: _____

Mailing Address: _____

Building Representative (signature): _____

The items on the checklist below shall be inspected and tested. This list does not constitute all of the required inspecting and testing of the fire and life safety system. Refer to the International Fire Code for inspecting and testing requirements.

Fire Sprinklers - Wet System Functionality

Flow Test conducted? Yes No

Static pressure: _____ psi Flow pressure : _____ psi

Number of Sprinkler Heads: _____

2-inch Drain? Other _____ Yes No

Flow switches, supervisory switches and alarm bells tested? N/A Yes No

Alarm bell operates? N/A Yes No

System inspected and lubricated? Yes No

Pressure regulating valves tested?? Yes No

Valves are sealed or supervised? Yes No

Signs are provided on valves? Yes No

Pumper connections and clapper valves unobstructed and turn freely? Yes No

Wet type sprinkler heads replaced or successfully sample tested in last 50 years? Yes No

Sprinkler coverage is acceptable? Yes No

Proper number of spare sprinkler heads available? Yes No

System left in service? Yes No

System gauges replaced or calibrated within the last 5 years? Yes No

Sprinkler heads free of corrosion, paint, obstructions and/or physical damage? Yes No

Was debris found in the Fire Department Connection (FDC)? Yes No

Was an internal pipe and valve inspection performed within the last 5 years? Yes No

Was a signal received at the Central Station monitoring company? N/A Yes No Date performed _____

Sprinkler wrench available for each type of sprinkler? Yes No
