



NOTES:

- 1) ROCK WALL SHALL BE BUILT PER SECTION 8-24 OF THE WSDOT STANDARD SPECIFICATIONS.
- 2) FENCE OR ACCEPTABLE ALTERNATIVE SHALL BE REQUIRED IF THE HEIGHT OF THE EXPOSED FACE OF THE WALL IS OVER 30 INCHES.
- 3) SET TOP ROW OF ROCK IN CEMENT CONCRETE GROUT APPROX. 1 INCH THICK.
- 4) H NOT TO EXCEED 5 FEET.

(NOT TO SCALE)



Pierce County

Public Works and Utilities
 Office of the County Engineer
 Tacoma Mall Office Building
 4301 South Pine Street, Suite 446
 Tacoma, Washington 98409-7207
 An APWA Accredited Agency



BRIAN D. STACY, P.E.
COUNTY ENGINEER

Office of the County Engineer

**ROCK WALL
 IN CUT**

PC.D1.1